

# Pressure Field Extension Testing

Gunnar Barr  **OBAR**  
SYSTEMS, INC.




Indoor Environments™ 2023 - Radon and Vapor Intrusion Symposium

# Topics

- Why Diagnostics?
- Designing Systems
- Pressure Field Extension Testing Equipment
- Pressure Field Extension Testing Process
- Examples



# Why Diagnostics? – Side by Side Buildings (Michigan)




450' of Horizontal Drilling – 1 Fan

	Distance (ft.)	Series 1
Airflow Yield (cfm)		5
Applied Vacuum ("w.c.)		30
SSP 1 (1' from applied)		12
T-1	10	0.1340
T-2	20	0.0020
T-3	30	BG
T-4	40	BG
T-5	10	0.0210
T-6	20	BG
T-7	30	BG
T-8	10	0.9270
T-9	20	0.0060
T-10	30	BG
T-11	10	0.3740
T-12	20	0.0020
T-13	30	BG

12' ROI  
30" w.c. applied

	Distance (ft.)	Series 1	Series 2
Airflow Yield (cfm)		7	<5
Applied Vacuum ("w.c.)		30	20
SSP 1 (1' from applied)		10	7.5
T-1	5	1.1000	0.7510
T-2	10	0.7010	0.5210
T-3	15	0.5100	0.7310
T-4	25	0.1010	0.1830
T-5	35	0.0640	0.1210
T-6	45	0.0160	0.0760
T-7	40	0.1020	0.0900
T-8	30	0.1080	0.1010
T-9	55	0.0190	0.0130

55' ROI  
8" w.c. applied



5 Suction Pits  
1 Fan

OBAR Systems Inc.  
2896 Rt. 23 South  
Newfoundland, NJ 07435  
**OBAR**  
Mitigation Specialist  
Gunnar Barr  
NJDEP MIS 10056

# Mitigation Using Sub Slab Depressurization Systems (SSD)

- Designed to:
  - Meet a minimum sub slab vacuum
  - Apply vacuum to the soil below the slab through pits
  - Discharge soil gas outside the building
  - Run continually
  - Mitigate not remediate



# Designing SSDS – Required Information – A.R.E.

- **A**ppplied Vacuum
  - Expressed in inches of water column or pascals
- **R**esulting Airflow Yield
  - Expressed in Cubic Feet Per Minute
- **E**ffected Area
  - Expressed as radius of influence (ROI)



# Obtaining design data through Pressure Field Extension Testing (PFE)

- Pressure Field Extension Testing
  - Apply vacuum through diagnostic suction pits
  - 2-3 inch holes
  - Record applied vacuum
  - Record airflow yield
- Record vacuum at diagnostic test holes
  - ~ 3/8 inch holes
  - Various distances from suction pit
- Run test at multiple fan speeds
- Detailed building drawing



# PFE Testing Equipment

Exposure Safety

1

2

4

3

1. Head
2. Inline HEPA Filter
3. Custom Diagnostic Fan
4. Carbon on Exhaust



# PFE General Process

- Select diagnostic suction pits locations that can be used as permanent suction pit locations
- Test near interior and exterior walls and columns
- Determine test speeds based on initial readings
- Test for sub slab communication across footings, grade beams, and tenant spaces
- Look for sub slab anomalies
- Don't stop collecting data until you are confident with the results






# Anomalies

- Soil types
- Grade Beams
- Utility Trenches
- Elevation Changes
- Drainages Systems
- Settling in high traffic areas




# Safety Concerns



# Case Study

- NYC Suburb
- Warehouse
- 25,000 square Feet
- Two tenants





- 4 People – 1 Day
- 7 Diagnostics Suction Pits
- 43 Test Holes
- 90 Data Points



Settling along  
perimeter walls

Compacted  
native fill



Isolated  
slab

Crushed  
stone

Sandy  
Soils



# Gathering Data

Various distances and directions from applied vacuum

Resulting airflow yields (cfm)

2 different applied vacuum levels ("w.c.)

	Distance (ft.)	Series 1	Series 2
Airflow Yield (cfm)		45	30
Applied Vacuum ("w.c.)		20	12
T-1	10	0.104	0.071
T-2	20	0.012	0.005
T-3	30	0.005	BG
T-4	40	BG	BG
T-5	10	0.701	0.495
T-6	20	0.150	0.111
T-7	30	0.003	0.002
T-8	40	0.003	BG
T-9	10	0.129	0.091
T-10	20	0.018	0.011
T-11	30	0.002	0.002
T-12	10	0.205	0.155
T-13	20	0.050	0.040
T-14	30	0.002	0.002

20' ROI  
12" w.c. applied  
30 cfm airflow  
yield

# Gathering Data

	Distance (ft.)	Series 1	Series 2
Airflow Yield (cfm)		15	10
Applied Vacuum ("w.c.)		20	12
T-38	10	0.239	0.143
T-39	20	0.011	0.027
T-40	30	0.009	0.004
T-41	10	0.247	0.137
T-42	20	0.036	0.051
T-43	30	0.021	0.180

Resulting airflow yields (cfm)

2 different applied vacuum levels ("w.c.)

30' ROI  
12" w.c. applied  
10 cfm airflow yield

# Gathering Data

	Distance (ft.)	Series 1
Airflow Yield (cfm)		40
Applied Vacuum ("w.c.)		1.8
SSP 1 (1' from applied)		1.4
T-31	10	1.30
T-35	15	1.230
T-36	20	1.330
T-37	38	1.270




- It's rare
  - But it happens
- Justifies extensive diagnostics

ROI in excess of room size  
1.8" w.c. applied  
40 cfm airflow yield






# Final Design



21 suction points  
2 mitigation fans  
3 mechanical pushes


# Another look at ROIs

	D	SUCTION POINT 1			MAX	BG	DATE	T	W
		V1	V2	V3					
		52	37	23	67	0.001	01/06/15	25	snw
CFM									
SSP 1		4.9	2.8	1.57	71				
SSP 2									
PORT		20	10	5					
T1	10	1.5400	0.9500	0.5600					
T2	20	0.8200	0.5000	0.3100					
T3	30	0.4800	0.2900	0.1700					
T4	40	0.3700	0.2200	0.1300					
T5	50	0.2700	0.1500	0.0780					
T6	10	1.4000	0.8700	0.5300					
T7	20	0.9500	0.6300	0.3700					
T8	30	0.6600	0.4200	0.2600					
T9	40	0.5000	0.3200	0.2000					
T10	50	0.3400	0.2200	0.1400					
T11	10	1.2800	0.8050	0.4620					
T12	10	0.6500	0.4190	0.2410					
T13	30	0.5670	0.3590	0.2100					
T14	40	0.4100	0.2610	0.1690					
T15	50	0.1970	0.1250	0.0790					
T16	10	1.3200	0.0890	0.4910					
T17	20	0.9370	0.5890	0.3590					
T18	30	0.4950	0.3080	0.1890					
T19	40	0.1680	0.1070	0.0610					
T20	50	0.1380	0.0790	0.0500					
T21	60	0.0490	0.0530	0.0390					
T22	70	0.0520	0.0320	0.0210					
T23	80	0.0220	0.0130	0.0100					
T24	90	0.0130	0.0070	0.0060					
T25	100	0.0060	0.0040	0.0030					
T26	60	0.1200	0.0770	0.0420					
T27	70	0.0500	0.0280	0.0150					
T28	80	0.0600	0.0330	0.0200					
T29	90	0.0300	0.0150	0.0090					
T30	100	0.0200	0.0110	0.0080					
All values negative unless preceded by a P									
BG= Background									




# Another look at ROIs

D	SUCTION POINT 2			MAX	BG	DATE	T	W
	V1	V2	V3					
CFM	78	48		85		01/06/15	25	snw
SSP 1	3.9	2.2		4.3				
SSP 2								
PORT	20	10						
T20	10	1.6600	0.9610		p.001			
T19	20	1.0600	0.6160					
T18	30	0.6010	0.3440					
T17	40	0.2330	0.1310					
T16	50	0.1210	0.0640					
T6	60	0.0830	0.0430					
T11	70	0.0560	0.0330					
T12	80	0.0380	0.0210					
T13	90	0.0350	0.0200					
T14	100	0.0270	0.0150					
T15	110	0.0170	0.0120					
T31	10	1.6800	0.9380					
T32	20	1.0700	0.6180					
T33	30	0.4900	0.2690					
T34	40	0.2700	0.1380					
T35	50	0.1700	0.0780					
T36	60	0.1000	0.0390					
T37	70	0.0800	0.0270					
T38	80	0.0400	0.0270					
T39	90	0.0280	BG					
T40	100	0.0200	BG					
T41	10	0.0060	0.0040					
T42	20	0.0070	0.0040					
T43	30	0.0080	0.0040					
T44	40	0.1000	0.0050					
T45	50	0.0130	0.0070					
T46	60	0.0100	0.0050					
T47	70	0.0050	0.0020					
T48	80	BG	BG					
T49	90	BG	0.0010					
T50	100	BG	BG					
T51	10	1.5900	0.9140					
T52	20	0.7510	0.4300					
T53	30	0.5790	0.3310					
T54	40	BG	BG					
T55	50	0.2810	0.1570					
T56	60	0.0210	0.0110					
BG= Background								
all values are negative unless preceded by a P								




# Another look at ROIs

	D	SUCTION POINT 3			MAX	BG	DATE	T	W
		V1	V2	V3					
CFM		100	75	50					
SSP 1		4.3	2.9	1.7					
SSP 2									
PORT		16	10	5.4					
T50	10	1.1300	0.8820	0.5040					
T49	20	0.3920	0.2770	0.1760					
T48	30	NA	NA	NA					
T47	40	0.0690	0.0480	0.0300					
T46	50	0.0340	0.0210	0.0130					
T45	60	0.0350	0.0240	0.0150					
T44	70	NA	NA	NA					
T43	80	0.0040	0.0010	BG					
T42	90	BG	BG	BG					
T41	100	BG	BG	BG					
T40	110	BG	BG	BG					
T57	10	1.3270	0.9340	0.5760					
T58	20	0.7730	0.5520	0.3420					
T59	30	0.3600	0.2650	0.1590					
T60	40	0.1460	0.1060	0.0650					
T61	50	0.0880	0.0650	0.0400					
T62	60	0.0200	0.0150	0.0110					
T63	70	0.0070	0.0060	0.0050					
T44	80	0.0050	0.0040	0.0030					
T65	90	0.0020	0.0030	0.0020					
T66	100	BG	BG	BG					
T67	10	0.8750	0.5960	0.3690					
T68	20	0.3480	0.2740	0.1370					
T69	30	0.1500	0.1310	0.0870					
T70	40	0.0820	0.0580	0.0360					
T71	50	0.0460	0.0580	0.0360					
T72	60	0.0110	0.0070	0.0040					
T73	70	0.0020	BG	BG					
T74	80	BG	BG	BG					
T75	90	BG	BG	BG					
T76	100	BG	BG	BG					
T77	10	0.9370	0.7280	0.4440					
T78	20	0.2720	0.2010	0.1310					
T78	30	0.1030	0.0770	0.0510					
T80	40	0.0570	0.0440	0.0290					
T81	50	0.0360	0.0270	0.0180					
T82	60	0.0240	0.0190	0.0130					
T83	70	0.0180	0.0150	0.0100					
T84	80	0.0090	0.0080	0.0060					
T85	90	0.0060	0.0070	0.0040					
T86	100	BG	BG	BG					
All values negative unless preceded by a P									
BG= Background									




# Another look at ROIs

	D	SUCTION POINT 4			MAX	BG	DATE	T	W
		V1	V2	V3					
CFM		27			45	11/07/14	15	CL	
SSP 1		0.9			1.7				
SSP 2									
PORT		20			43				
T76	10	0.0610							
T75	20	0.0230							
T74	30	0.0040							
T73	40	0.0020							
T72	50	0.0010							
T71	60	0.0010							
T70	70	BG							
T69	80	BG							
T68	90	BG							
T67	100	BG							
T87	10	0.0920							
T88	20	0.0590							
T89	30	0.0070							
T90	40	0.0030							
T91	50	BG							
T92	60	BG							
T93	70	BG							
T94	10	0.0620							
T95	20	0.0300							
T96	30	0.0060							
T97	40	0.0030							
T98	50	BG							
T99	60	BG							
T100	70	BG							
T101	80	BG							
T102	90	BG							
T103	100	BG							
T104	10	0.1930							
T105	20	0.0430							
T106	30	0.0060							
T107	40	0.0040							
T108	50	BG							
T109	60	BG							
T110	70	BG							
T111	80	BG							
T112	90	BG							
T113	100	BG							
All values negative unless preceded by a P									
BG= Background									




# Another look at ROIs

	D	SUCTION POINT 5			MAX	BG	DATE	T	W
		V1	V2	V3					
		47	27			01/07/15	25	clr	
CFM		6.2	3.6		67				
SSP 1					9.9				
SSP 2									
PORT		20	10						
76	20	0.0370	0.0200		0.001				
75	25	0.0360	0.0210						
74	35	0.0140	0.0070						
73	45	0.0050	0.0020						
72	55	na	na						
71	65								
70	75								
69	85								
68	95								
67	105								
87	10	0.0490	0.0280		P.002				
88	20	0.0550	0.0320						
89	30	0.0060	0.0030						
90	40	0.0010	BG						
91	50	na							
92	60	na							
93	70	na							
94	30	0.0160	0.0100						
95	40	0.0100	0.0060						
96	50	0.0020	0.0020						
97	60	0.0010	0.0010						
98	70		0.0010						
99	80								
100	90								
101									
102	100								
103	110								
104	10	0.6200	0.3550						
105	0								
106	10	0.2290	0.1400						
107	20	0.0780	0.0450						
108	30	0.0200	0.0130						
109	40	0.0100	0.0080						
110	50	0.0030	0.0030						
111		0.0020	BG						
112	60	0.0010	BG						
113	70								
		BG= Background							
		All Values are negative unless preceded by a P							



# Another look at ROIs

D	SUCTION POINT 6			MAX	BG	DATE	T	W
	V1	V2	V3					
				24	0	01/07/15	15	CL
CFM	12	9	7					
SSP 1	0.6	0.366	0.238	1.1				
SSP 2								
PORT	20	10	5					
T114	10	0.0970	0.0590	0.0380				
T115	20	0.0280	0.0170	0.0120				
T116	30	0.0080	0.0060	0.0040				
T117	40	0.0060	0.0040	0.0030				
T118	50	0.0040	0.0020	0.0020				
T119	10	0.1070	0.0630	0.0410				
T120	20	0.0670	0.0390	0.0260				
T121	30	0.0380	0.0220	0.0140				
T122	40	0.0600	0.0110	0.0070				
T123	50	0.0110	0.0100	0.0070				
82		0.0700	0.0420	0.0290				
81		0.0220	0.0140	0.0090				
124	37	0.0090	0.0050	0.0040				
57	58	0.0010	BG	BG				
79		0.0130	0.0070	0.0050				
80		0.0220	0.0140	0.0090				
83		0.0700	0.0420	0.0290				
All values negative unless preceded by a P								
BG= Background								
T								



# Don't Forget

- Vapor Intrusion is Pressure Differential Driven
- Sub Slab Depressurization is our best tool for mitigation
- Design using A.R.E. (Applied, Resulting, Effected)
- Proper Pressure Field Extension Technique is key
  - Safety
  - Thorough
  - Don't stop collecting data until you are confident in results

Thanks for listening!!

[gbarr@ObarSystems.com](mailto:gbarr@ObarSystems.com)

