

***Mitigation Diagnostics
for
Schools
&
Large Buildings***

Bill Brodhead
WPB Enterprises, Inc
www.wpb-radon.com

wmbrodhead@gmail.com
610 613-8004

How do you design an ASD system for this 10 story building?



Lowest level
radon
12 to 24 pCi/L

Owner requests
no outside piping?

Important Commercial Building Questions:

How old is the building?

1940 - 1950

Was there any additions?

No

Are there construction drawings?


No


Does HVAC provide outdoor air?

Yes but unknown

Can it be fixed with outdoor air?

No





Important PFE question

What is the PFE
Radius of Influence?

ROI

20 ft ROI @ V3

1,250 Sq Ft

70 ft ROI @ V2



15,000 Sq Ft

Need **twelve**

V3 ROI suction pits
to cover **one** V2 ROI area

A Larger fan may double CFM but will not double ROI

Rule:
Square of
CFM change
equals
Pressure
Change




Airflow 2.3 X - Baseline 4.2 X - All Test Holes 3.1 to 3.4 X

PFE began 30 years ago

EPA published:
Bruce Henschel's
Residential ASD
Technical Guidance
on
Pressure Field
Extension (PFE).

Residential PFE Concepts
are
the same for
Commercial Buildings



Thank you Bruce

Main
Difference:

Residential: uses Suction pit PFE during installation

Commercial: makes Multi Pre-Installation PFE Tests


Commercial PFE:

Core 2.5"

Vacuum out
1 to 1.5 gallons

Measure
CFM
&
Baseline Pressure
=

**Subslab
Airflow Resistance**




Which Baseline test hole distance best simulates a dug out suction pit?

8" out or 12" out?


The Test

Measured
3
PFE Airflows
with
a pitot tube
in a
2" riser pipe.



Measure Baseline Sub-Slab Pressure
8" & 12"

Comparison of Garage PFE results vs Dug Out suction pit




I recommend a Baseline Distance of 8"

10 Story
Case
Study
S1 PFE

Vacuum off test holes +4 to +7 PA DR +20 Pa

Building pressure In to Out was – 34 Pascals



S1- 141 CFM & ROI 20' X 70'

Case
Study
S2 PFE

210 foot ROI
S2 used a sump pit for PFE test




S2 airflow 162 CFM S1 airflow 141 CFM
8" Baseline only 0.28" SP - S1 0.52" SP

Case
Study
S2 PFE

Baseline Sub-Slab 0.28"
200 ft of 4" piping is 2.0" Pressure Drop

4" Piping is
88%
of
Total
System
airflow
resistance

Solid Red
is
PFE test
+
piping



Dashed is
extrapolated
higher
airflow

GBR89 can move 340 CFM versus 162 CFM during PFE Testing

Case
Study
S3 PFE


Very
Different
Results

$$S2 \text{ ROI} = 40' \times 210' = 8400 \text{ ft}^2$$

vs

$$S3 \text{ ROI} = 30' \times 70' = 2100 \text{ ft}^2$$

4X different sq ft



$$S2 = 55 \text{ CFM} \text{ vs } S3 = 162 \text{ CFM}$$

3X different CFM

$$8'' \text{ Baseline } S2 = 6.4'' \text{ SP vs } S3 = 0.28'' \text{ SP}$$

20X different SP

Case
Study
S3
Fan
&
Piping
Size


Big Difference in fan choice

GBR76 SOE = 300 watts

GBR89 = 1000 watts

S3 - Baseline = 6.0" SP

200 ft of 3" piping = 1.5" SP



3" Piping
only
15%
Total
System
Airflow
Resistance


Case
Study
S4 PFE

Airflow
only
17 CFM

Baseline
SP
11.6"

S4 20 X 30 ft ROI = 600 ft² @ 17 CFM
S3 30 X 70 ft ROI = 2100 ft² @ 55 CFM
S2 at 40 X 210 ft ROI = 8400 ft² @ 162 CFM

S4
14 X more
Sq Ft



S4 PFE did not reach across Dining Room


Case
Study
S4 PFE

200 ft 3" pipe = 0.2" SP

200 ft 2" = 0.8" SP

High Vacuum
GBR76 UD
best choice

2" Piping
is only
6%
of
Total
System
airflow
resistance




Fan speed
is
adjustable

Recommended
Suction Pit
Trenching
Increase
Airflow

$$\text{Piping Pressure Drop} = +((0.205 * \text{CFM} * \text{Pipe inch size}^{1.7})^{2.5}) * (\text{Total EF}/100)$$

Critical
to
Calculate
Piping
Pressure
Drop



Derived from
30 & 60 foot
lengths of
piping tested




Piping Pressure Drop Formula & chart at www.WPB-radon.com

Critical to add equivalent feet for all fittings used

Fitting EF
from 20' of
Piping


Pipe Size	Sweep 90°	Hard 90°	Sweep 45°	Angled 45°	Pipe Reducer	Open Inlet
2"	3'		2'			6.5'
3"	5'	14'	2'	4'	23'	21'
4"	6'	20'	3'	6'	16'	28'
6"	15'	26'	7'	11'	52'	40'



Angled Turn elbows have twice the pressure drop of sweeps

Formula for each fitting Equivalent Feet at CFM flow in Pressure Drop Paper

System #1 & #2 performance equaled PFE test at S2 & S3



S4 PFE
predicted
32 CFM
System #3
had
65 CFM
because of
trenching

Least sub-slab vacuum was - 3.2 Pa or - 0.013"

Conference Papers on
Commercial PFE Testing
Calculating Piping Pressure Drop
Onsite Radon in Water Measurements
Elevation Influence

Available at:

www.wpb-radon.com

Bill Brodhead
WPB Enterprises, Inc
wmbrodhead@gmail.com
610 613-8004